## AUTOMATIC FIRE ALARM TEST REPORT



\*\*Only this document will be accepted by the Evesham Township Fire Prevention Division for fire alarm testing purposes as required by the New Jersey Uniform Fire Safety Code and applicable N.F.P.A. Standards

NOTE: ANY deficencies MUST be reported to the Fire Prevention Office at (856) 983-2750.

	on Division for the alarm testing olicable N.F.P.A. Standards
DATE: TIME:	
PROPERTY	NAME (USER)
PROPERTY Name:	NAME (USER)

	ORGANIZATION		PROPERTY NAME (USER)	
Name:			Name:	
Address:			Address:	
Representa	ative:			
License #: Telephone:			Telephone:	
Тогорглогіо				
	ING ENTITY		APPROVING AGENCY	
Contact:	-		Contact:	
Telephone: Monitoring	Account Ref. #:		Telephone:	
	NSMISSION		SERVICE	
□ McCull		□ Reverse priority		□ Semiannually
□ Multiple		□ RF		□ Annually
□ Digital	O.K		□ Quarterly	- / willdaily
_	(Specify)		Other (Specify)	
	it Manufacturer:		Model #:	
Circuit Style Number of				
Software R				
	System Had Any Service	ce Performed:		
Last Date t	hat Any software or Co	onfiguration Was Revised:		
		ALARM-INITIATING DEVICES A	AND CIDCUIT INFORMATION	
Qty	Circuit Style	ALARM-INITIATING DEVICES A	Qty Circuit Style	
Qty	On our otylo	Manual Fire Alarm Boxes	Ground Otylic	Heat Detectors
		Ion Detectors	<del></del>	Waterflow Switches
		Photo Detectors	<del></del>	Supervisory Switches
		Duct Detectors		Other (Specify)
Alarm verifi	ication feature is disab	led: enabled:		
, uai i i voi i i	isation routare to disub	<del></del>		
Qty	Circuit Style	ALARM NOTIFICATION APPLIANC	ES AND CIRCUIT INFORMATION  Qty Circuit Style	
Qty	Circuit Style	Bells	Qty Circuit Style	Strobes
		Horns	<del></del>	
		Chimes		Speakers Other (Specify)
	alarm notification applied monitored for integrity	·		
7 0 0 0 0	· ····o·····c··························			
Qty	Circuit Style	SUPERVISORY SIGNAL-INITIATING DE	Qty Circuit Style	
Qty	On out Otylo	Building Temp	Girodic Style	Fire Pump Power
		Site Water Temp		Fire Pump Running
		•		Fire Pump Running Fire Pump Auto Position
		Site Water Level		•
		Generator in Auto Position		Fire Pump Trouble
		Generator or Controller Trouble		Fire Pump Controller Troub
		Switch Transfer		Other: (Specify)
		Generator Engine Running		
SIGNALIN	G LINE CIRCUITS			
		e circuits connected to system (see NFPA 7	2. Table 6.6.1):	
Quantity:	, 5 - 5	Style(s):	,	

Phone: (856)983-2750, Fax: (856)797-2069, Email: firemarshal@eveshamfire.org

SYSTEM POWER SUPPLI	ES						
(a) Primary (Main): Nominal Voltage				Amps			
Overcurrent Protection	-		Amps				
Location (of Primary St			-				
Disconnecting Means I							
(b) Secondary (Standby):							
Storage Battery: Amp-I	Hr Rating						
Calculated capacity in		Amp-Hrs to	operate system	for h	ours		
	or dedicated to fire alarm		-,				
Location of fuel storage		-,		-			
_							
TYPE BATTERY							
	ickel-Cadmium	Sealed Lea	d-Acid	□ Lead-Acid			
Other: (Specify)							
(c) Emergency or standby	•			-	ry power supply:		
	Emergency system de						
	Legally required stand	-					_
		em described ir	n NFPA 70, Artic	cle 702 which also meet	s the performance require	ements of	,
	Article 700 or 701						
		PRIC	OR TO ANY TES	STING			
<b>NOTIFICATIONS ARE MA</b>	DE	Yes	No	Who	Tim	е	
Monitoring Entity							
Building Occupants							
Building Management							
Other (Specify)							
AHJ Notified of Any Impairs	ments						
		01/0==110					
			TESTS AND IN				
TYPE	Visual	Function	onai	Comments			
Control Unit							
Interface Equipment							
Lamps/LEDs							
Fuses							
Primary Power Supply							
Trouble Signals							
Disconnect Switches							
Ground-Fault Monitoring							
SECONDARY POWER							
TYPE	Visual	Function	onal	Comments			
Battery Condition							
Load Voltage							
Dicharge Test							
Charger Test							
Specific Gravity							
,	Visual	Functi	onal	Comments			
TRANSIENT SUPPRESSO	ORS 🗆						
DEMOTE ANUMAIATADA							
REMOTE ANUNCIATORS				-			
NOTIFICATION APPLIANCE	CES						
Audible							
Visible							
Speakers							
Voice Clarity							
	INITIATING	AND SUBERY	ISOBA DEVICE	TESTS AND INSPECT	TIONS		
Loc. & S/N		AND SUPERV sual	Functional		IIONO	Pass	Fail
LOC. & 3/N		suai neck	Test	Factory Setting	Measured Setting	газэ	Ган
	Type Ch			Setting	wicasureu setting	Б	
					_		
			ш		_	ш	ш
Comments:							

Phone: (856)983-2750, Fax: (856)797-2069, Email: firemarshal@eveshamfire.org

EMERGENCY COMMUNICATIONS EQUIPMENT	Visual	Functional		Comments
Phone Set				
Phone Jacks				
Off-Hook Indicator				
Amplifier(s)				
Tone Generator(s)				
Call-in Signal				
System Performance				
COMBINATION SYSTEMS	Visual	Device Operatio	n Sir	nulated Operation
Fire Extinguisher Monitoring Device/System				
Carbon Monoxide Detector/System (Specify)				0
INTERFACE EQUIPMENT				
(Specify)				
(Specify)				
(Specify)				
SPECIAL HAZARD SYSTEMS	_	_		
(Specify) (Specify)				
(Specify)				
Special Procedures:				
Comments:				
SUPERVISING STATION MONITORING	Yes	No Ti	me	Comments
Alarm Signal	_			Comments
Alarm Restoration				
Trouble Signal	_			
Trouble Signal Restoration				
Supervisory Signal				
Supervisory Restoration				
NOTIFICATION THAT TESTING IS COMPLETE	-	_	Who	Time
Building Management Monitoring Agency				
Building Occupants				
Other (Specify)				
The following did not operate correctly:				
System restored to normal operation: Date:	Time	e:	_	
THIS TESTING WAS PERFORMED IN ACCORDANCE WITH APP	PLICABLE NFPA STAND	OARDS		
Name of Inspector:	Date:		Time:	
Signature:	_		-	<del></del>
Name of Owner or Representative:	Date:		Time:	
Signature:	Daic.		· IIIIG.	
olynature.				

Phone: (856)983-2750, Fax: (856)797-2069, Email: firemarshal@eveshamfire.org